



The City of Wildwood Fire Department

4400 New Jersey Avenue
Wildwood, New Jersey 08260
Phone 609-846-2030
Fax 609-522-4965
fireprev@wildwoodnj.gov

Ernest Troiano III., CPM
Fire Chief

Jacob M. Spiegel
Fire Official

Mobile Food Preparation Vehicle Guidelines (LP-Gas Systems)

FIRE SAFETY PERMIT: Mobile food preparation vehicles require a Type 1 permit pursuant to N.J.A.C. 5:70-2.7(a)3.xix. and City of Wildwood Local Code, Chapter 13A-1.9A. A permit should be applied 14 business days or more prior to the event. A permit applied for less than 14 business days from the event may be subject to the permit fee doubled. Permits shall be paid in full prior to the event. No permit applications will be accepted the day of the event. The permit fee is non-refundable.

FUEL GAS SYSTEM: LP-Gas containers on the vehicle **and** fuel-gas piping systems shall be inspected at least annually by a licensed plumber. **Documentation of such shall be submitted with the permit application.** LP-Gas cylinders shall be securely mounted and restrained on the vehicle and not exceed 200lbs propane capacity.

EXHAUST SYSTEM & EXTINGUISHING AGENT: All cooking operations that produce grease laden vapors shall be equipped with an exhaust system and alternative automatic fire extinguishing system in accordance with NJ IFC 2018 and NFPA 96. Systems shall be tested and maintained to such requirements.

FIRE EXTINGUISHERS: Fire extinguishers shall comply with NJ IFC 2018. Class K fire extinguishers are required for the following: cooking with vegetable or animal oils and fats, cooking with solid fuel, and cooking with deep fat fryers. A 2-A:10-B:C fire extinguisher is required in addition to a Class K extinguisher.

LOCATION OF VEHICLE/ TRAILER & GENERATOR(S): Shall be kept not less than 10' from any buildings, combustibles, means of egress, and other preparation vehicles.

GAS DETECTION: A listed LP-gas alarm shall be installed within the vehicle in the vicinity of LP-gas system components.

MISCELLANEOUS: All appliances shall be listed and labeled for commercial use and secured in place with an appliance's connector complying with ANSI Z21.69/CSA 6.16. **All testing and maintenance documentation shall be kept in the vehicle and presented at the time of inspection.**

Type 1 Permit (see description below) - \$75.00 when submitted at least 14 business days prior to the event.

Mobile or temporary food preparation activities, where open flame or flame-producing devices or appliances are used, or grease-laden vapors are produced.

Failure to adhere to the specific conditions of the permit set by the Fire Official will result in revocation of the permit and up to a \$500.00 penalty